

Rupture Basin Tank Testing

When was the last time the sensors were tested on your Rupture Basin Tank?



When Rupture Basin Tank Sensors work properly, you'll be alerted to a leak before:

- Generators shut down
- There is a loss of power
- Environmental disasters and leaks occur
- You are cited for equipment failures

Avoid costly penalties: Annual inspections are required.

Annual Leak Detection Verification (Per CFC 5003.2.9 – 5004.2.2.5) The purpose of this service is to provide confirmation of existing alarms for secondary containment systems. During verification, the leak detection float sensors are removed and triggered manually to verify both audible and visual alarms. After verification, the sensors are reinstalled. The standard verification covers tanks with up to 4 sensors and alarms that are located either on the generator control panel or in the same room as the generator.

Enjoy peace of mind knowing that your tanks will continue to

- Hold up to 100% of your diesel fuel in the event of a leak
- Alert you immediately should a leak occur

Don't delay, Call today **925-229-2700 to schedule your inspection.**



GotPower.com
Contractor License 757162

Corporate Office

150 Nardi Lane
Martinez, CA 94553
Hours: 8:00am to 4:30pm
(925) 229-2700

Sacramento Office

4372 Pinell Street
Sacramento, CA 95838
Hours: 8:00am to 4:30pm
(916) 564-2622

24 Hour Emergency Service | 866-468-7697